



Type SASD

Spun Axial Supply

Power Roof Ventilators



* A HIGHER-THAN-STANDARD CURB MAY BE REQUIRED FOR CLEARANCE BETWEEN FAN MOTOR AND DAMPER WHEN A BACKDRAFT DAMPER IS USED.

AMERICAN COOLAIR CORPORATION

P.O. Box 2300 Jacksonville, Florida 32203
 Phone: (904) 389-3646
 Fax: (904) 387-3449 • (904) 381-7560
 E-mail: info@coolair.com
 Website: www.coolair.com

Standard Features

- Low-silhouette design
- Round spun aluminum hood
- Heavy gauge hood supports
- Designed to maintain flow rates at or below 625 FPM to prevent entrainment of moisture
- Galvanized wire bird screen

Optional Features

- Backdraft damper (motorized or automatic)
- Roof curb (damper shelf optional)
- Epoxy coating
- Insect screen

| Unit Size | Ventilator Dimensions | | | | | Roof Curb Dimensions | | | |
|-----------|-----------------------|--------|--------|----|-------|----------------------|--------|--------|--------|
| | A | B | C | D | E | F | G | H | K |
| 12 | 18 | 20 7/8 | 13 | 12 | 4 1/4 | 24 1/2 | 11 1/4 | 16 1/2 | 13 1/4 |
| 16 | 23 | 28 5/8 | 12 3/8 | 16 | 6 1/4 | 29 1/2 | 16 1/4 | 21 1/2 | 18 1/4 |
| 20 | 30 | 39 5/8 | 15 3/8 | 20 | 6 1/2 | 36 1/2 | 23 1/4 | 28 1/2 | 25 1/4 |
| 25 | 34 | 43 5/8 | 16 3/4 | 25 | 9 | 40 1/2 | 27 1/4 | 32 1/2 | 29 1/4 |
| 31 | 40 | 48 5/8 | 18 1/8 | 31 | 9 | 46 1/2 | 33 1/4 | 38 1/2 | 35 1/4 |
| 37 | 46 | 62 7/8 | 22 1/8 | 37 | 9 | 52 1/2 | 39 1/4 | 44 1/2 | 41 1/4 |

Dimensions in Inches

Specifications

| FAN NO. | QTY. | FAN DATA | | | | | MOTOR DATA | | | | | | ACCESSORIES AND REMARKS | |
|---------|------|-----------|-----|----|-----|-------|------------|-----|---------|----|----|-----------|-------------------------|--|
| | | MODEL NO. | CFM | SP | RPM | SONES | HP | RPM | VOLTAGE | PH | HZ | ENCLOSURE | | |
| | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | |

PROJECT _____ ENGINEER _____ SUBMITTED BY _____ DATE _____
 LOCATION _____ CONTRACTOR _____ APPROVED BY _____ DATE _____